



Ref. Certif. No.

SE-110983

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Type B residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)

Name and address of the applicant

Zhejiang ETEK Electrical technology Co., Ltd.
NO.288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang Province, P.R.China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Additional Information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See page 2

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

EKL5-63B, EKL15-63B

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62423:2009
IEC 61009-2-2:1991
IEC 61009-1:2010+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

230201034SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 09 May, 2023

Signature:

Quan Li



Ref. Certif. No.

SE-110983

Factories

Factory 1: Zhejiang ETEK Electrical technology Co., Ltd
address: NO.288 Wei 17th Road, Yueqing Economic Development Zone Yueqing, Wenzhou,
Zhejiang Province, P.R.China

Factory 2: ETEK Electrical Wuhu Co., Ltd.
address: No.770 Wutun Fast Road, Anhui Xinwu Economic Development Zone, Wanzhi District,
Wuhu City, Anhui Province, P.R.China

Ratings and principal characteristics

$U_n = 230V\sim(240V\sim)$ for 2P(1P+N), $400V\sim(415V\sim)$ for 4P(3P+N), 50/60Hz
 $I_n = 6, 10, 16, 20, 25, 32, 40, 50, 63A$; B-&C-&D-type
 $I_{\Delta n} = 30mA, 100mA, 300mA$, type-B
 $I_{cn} = 10000A, I_{cs} = 7500A, I_{cn} = I_{cs} = 6000A, I_{\Delta m} = 3000A$
Energy limiting class 3 for B-&C-type 10kA

Date: 09 May, 2023

Signature: