



Ref. Certif. No.

SE-108958M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge protective device

Name and address of the applicant

Zhejiang ETEK Electrical technology Co., Ltd.
No. 288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang, China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Same as applicant

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

TYPE 2 SPD, Uc: 275V/385V~, In:20kA, Imax: 40kA, Up: 1.3kV/1.5kV/1.8kV

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

See page 2

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

211201972SHA-001, 211201972SHA-001 M1

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 10 November, 2022

intertek

Signature: 

Gary Hu

Model / Type Ref.

EKU5-T2-40-1P275, EKU5-T2-40-2P275, EKU5-T2-40-3P275, EKU5-T2-40-4P275, EKU5-T2-40-1PN275, EKU5-T2-40-3PN275, EKU5-T2-40-1P385, EKU5-T2-40-2P385, EKU5-T2-40-3P385, EKU5-T2-40-4P385, EKU5-T2-40-1PN385, EKU5-T2-40-3PN385

Additional information

Model	Protected mode	In (kA)	I _{max} (kA)	U _c (V)	U _p (kV)	LV System
EKU5-T2-40-1P275	L-PE	20	40	275	1.3	TN
EKU5-T2-40-2P275	L/N-PE					
EKU5-T2-40-3P275						
EKU5-T2-40-4P275						
EKU5-T2-40-1PN275	L-N	20	40	275	1.3	
	N-PE	20	40	255	1.5	
EKU5-T2-40-3PN275	L-N	20	40	275	1.3	
	N-PE	20	40	255	1.5	
EKU5-T2-40-1P385	L-PE	20	40	385	1.8	TN
EKU5-T2-40-2P385	L/N-PE					
EKU5-T2-40-3P385						
EKU5-T2-40-4P385						
EKU5-T2-40-1PN385	L-N	20	40	385	1.8	
	N-PE	20	40	255	1.5	
EKU5-T2-40-3PN385	L-N	20	40	385	1.8	
	N-PE	20	40	255	1.5	

This certificate replaced the original CB certificate SE-108958 dated 02 September 2022. A new certificate is issued due to:

Add "N-PE" protection mode for model: EKU5-T2-40-2P275, EKU5-T2-40-3P275, EKU5-T2-40-4P275, EKU5-T2-40-2P385, EKU5-T2-40-3P385, EKU5-T2-40-4P385

Date: 10 November, 2022

Signature: 